

# Certificate of Compliance

Certificate Number 20060526- E251759  
Report Reference E251759, 2006 MAY 26  
Issue Date 2006 August 24

UL India Private Limited a Subsidiary of

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

*Issued to:* **KELTRON COMPONENT COMPLEX LTD**

Keltron Nagar, PO Kalliasseri,  
Kannur, 670562 India,

*This is to certify that  
representative samples of*

**Electrolytic Capacitors, Construction Only, Cat. No. MU Series**


Ratings:  
Input Voltage: 110 - 330 VAC  
Capacitance: 20 - 552 uF  
Frequency: 47 - 63 Hz

*have been investigated by UL India Pvt. Ltd. a subsidiary of Underwriters  
Laboratories Inc. ® according to the Standard(s) indicated on this Certificate.*


*Standard(s) for Safety:* **UL 810, standard for Capacitors, Fifth Edition and Canadian Standard C22.2 No.  
190, Capacitors for Power Factor correction, First Edition**

*Additional Information:* **NIL**


Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:   
**P.C SHIVALINGAM**

UL India Pvt. Ltd.

Reviewed by:   
**PEEYUSH GUPTA**

UL India Pvt. Ltd.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. UL India Pvt. Ltd.